


VA FORM 08-6231

SHEET NOTES:

- 1. SEE SHEET FP0.1 FOR SYMBOL LEGEND AND NOTES.
- 2. EQUIPMENT SHOWN ON THIS SHEET IS FOR REFERENCE ONLY; BASED ON VISUAL OBSERVATION AND AS-BUILT DOCUMENTATION. NOT ALL EQUIPMENT MAY BE SHOWN. CONTRACTOR IS RESPONSIBLE TO MODIFY EXISTING SPRINKLER AS NECESSARY TO PROPERLY PROTECT NEW CONSTRUCTION IN ACCORDANCE WITH NFPA 13.
- 3. DEMOLITION SHOWN ON THIS SHEET IS FOR REFERENCE ONLY.
 CONTRACTOR SHALL RE-USE EXISTING PIPING AND OUTLETS TO THE
 MAXIMUM EXTENT POSSIBLE WHILE COMPLYING WITH THE APPLICABLE
 CODES
- IF EQUIPMENT IS REMOVED, CONTRACTOR SHALL REMOVE ASSOCIATED PIPING ABOVE CEILINGS AND BEHIND WALLS TO THE MAXIMUM EXTENT POSSIBLE.
- 5. CONTRACTOR SHALL VERIFY THAT DISCONNECTING EQUIPMENT DOES NOT AFFECT OTHER FIRE SPRINKLER SYSTEM EQUIPMENT WITHIN THE BUILDING (I.E., STANDPIPE CONNECTIONS, OTHER SPRINKLER ZONES, ETC.). IF DEMOLITION AFFECTS OTHER EQUIPMENT OUTSIDE THE ZONE OF DEMOLITION, CONTRACTOR SHALL RE-INSTALL PIPING TO ANY EXISTING EQUIPMENT TO REMAIN, EVEN IF NOT ASSOCIATED WITHIN THE SCOPE OF DEMOLITION.
- 6. ALL REMOVED EQUIPMENT SHALL BE RETURNED TO VA. REMOVED PIPING SHALL BE DISPOSED OF BY THE CONTRACTOR.
- 7. CONTRACTOR SHALL PROVIDE ALL LABOR AND MATERIALS NECESSARY FOR THE SCOPE OF WORK INCLUDED HEREIN.
- 8. CONTRACTOR SHALL MAINTAIN EXISTING FIRE SPRINKLER SYSTEM IN OPERATIONAL CONDITION AT ALL TIMES UNLESS SPECIFICALLY APPROVED BY VA. EXISTING FIRE SPRINKLER SYSTEM SHALL NOT BE TAKEN OUT OF SERVICE.



FULLY SPRINKLERED

Project Title
RENOVATE ED + PRIMARY CARE Drawing Title CONSULTANTS: PROJECT MANAGERS AND ENGINEERS: Office of 667-10-100 FIRST FLOOR - EAST Construction **Building Number** FIRE PROTECTION DEMOLITION PLAN STEVEN E. UNGER License No. 36385 1N, 1E and Facilities HUGHES ASSOCIATES, INC.
FIRE PROTECTION ENGINEERS Approved: Project Director Location SHREVEPORT VAMC 510 EAST STONER AVE Drawing Number Management CODE CONSULTANTS Department of Veterans Affairs 3 EXECUTIVE COURT, UNIT 4 SOUTH BARRINGTON, IL 60010 2121 W. Spring Creek Parkway, Suite 108 Plano, Texas 75023 Phone 972-491-1900 820 Jordan Street, Suite 507 tel. 318.424.3700 Shreveport, LA 71101 fax 318.424.3764 **Dwg.** 91 of 112